

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-1597:119 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: TEPG-US, 91 Technology Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 Fax (978)731-8881

DESIGN: Model 430561 ionization type smoke detector. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: 8.5 – 35 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as ionization smoke detector for use with separately listed compatible fire alarm control units. Unit is intended for use with listee's listed bases (CSFM Listing No. 7300-1597:107).

XLf: 7271-1062:115

05-15-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 11, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager